



BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DADE FLAGLER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2901 FAX (305) 375-2908

NOTICE OF ACCEPTANCE (NOA)

United Coatings Manufacturing Company
190 E. Cataldo
Spokane Valley, WA 99016

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Roof Mate & Diathon Coating

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA #03-1223.02 and consists of pages 1 through 3.
The submitted documentation was reviewed by Frank Zuloaga, RRC



NOA No.: 04-0513.01
Expiration Date: 04/01/09
Approval Date: 08/05/04
Page 1 of 3

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cement-Adhesive-Coatings
Material: Elastomeric
Maximum Design Pressure N/A
Fire Classification: See Limitation #1

1. SCOPE

This approves "Roof Mate and Diathon" as a maintenance roof coating as manufactured by United Coatings Manufacturing Company, as described in this Notice of Acceptance.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Asphalt Technologies, Inc.	UCMC-004-02-01	ASTM D 6083	03/03/03
	UCMC-004-02-02	ASTM D 6083	05/17/03
	UCMC-004-02-02	ASTM D 6083	03/30/04
	Revised		
	UCMC-004-02-02	ASTM D 6083	06/22/04
	Revised	Fed. Spec. TTC-555B	

PHYSICAL PROPERTIES OF COMPONENTS

Trade names: Diathon Coating
Thickness: See System Approvals Below
Specifications: ASTM D 6083
Description: A acrylic elastomeric coating applied membrane applied at an application rate of;

- Foam Roofs: Apply Base Coat at a minimum rate of 1.5 gal/100 ft² and Finish Coat at a rate of 1.5 gal/100 ft².

Container Size: 5 and 55 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply specific Roof Assembly, Product Control Notice of Acceptance.



Trade names:	Roof Mate Coating
Thickness:	See System Approvals Below
Specifications:	ASTM D 6083
Description:	A water-based elastomeric coating applied membrane applied at an application rate of; <ul style="list-style-type: none"> • Metal Roofs: Apply Base Coat at a minimum rate of 1 gal/100 ft² and Finish Coat at a rate of 1 gal/100 ft². • EPDM, PVC and TPO Membranes: Apply Base Coat at a minimum rate of 1 gal/100 ft² and Finish Coat at a rate of 1.5 gal/100 ft². • Modified Bitumen and Built-Up-Roofs: Apply Base Coat at a minimum rate of 1.5 gal/100 ft² and Finish Coat at a rate of 1.5 gal/100 ft².
Container Size:	5 and 55 gallons. Note all precautions on container.
Systems Approvals:	Methods of application and quantities shall comply specific Roof Assembly, Product Control Notice of Acceptance.

LIMITATIONS

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire rating of this product.
2. Diathon and Roof Mate shall not be applied in inclement weather conditions.
3. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.
4. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to BCCO upon request.
5. All approved products listed herein shall be labeled in compliance with TAS I21.
6. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
7. Diathon and Roof Mate shall be applied in accordance with manufacturer's published application instructions.
8. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 04-0513.01
 Expiration Date: 04/01/09
 Approval Date: 08/05/04
 Page 3 of 3